

A novel solar-assisted ground-source heat pump (SAGSHP) with seasonal heat-storage and heat cascade utilization: field test and performance analysis

Article

Accepted Version

Creative Commons: Attribution-Noncommercial-No Derivative Works 4.0

Sun, T., Yang, L., Jin, L., Luo, Z. ORCID:
<https://orcid.org/0000-0002-2082-3958>, Zhang, Y., Liu, Y. and Wang, Z. (2020) A novel solar-assisted ground-source heat pump (SAGSHP) with seasonal heat-storage and heat cascade utilization: field test and performance analysis. *Solar Energy*, 201. pp. 362-372. ISSN 0038-092X doi: 10.1016/j.solener.2020.03.030 Available at <https://reading-pure-test.eprints-hosting.org/89411/>

It is advisable to refer to the publisher's version if you intend to cite from the work. See [Guidance on citing](#).

To link to this article DOI: <http://dx.doi.org/10.1016/j.solener.2020.03.030>

Publisher: Elsevier

All outputs in CentAUR are protected by Intellectual Property Rights law, including copyright law. Copyright and IPR is retained by the creators or other copyright holders. Terms and conditions for use of this material are defined in

the [End User Agreement](#).

www.reading.ac.uk/centaur

CentAUR

Central Archive at the University of Reading

Reading's research outputs online

1 Manuscript submitted to Solar Energy (revision): [March 2019](#)

2 **A novel solar-assisted ground-source heat pump (SAGSHP) with seasonal heat-storage**
3 **and heat cascade utilization: field test and performance analysis**

4 Tingting Sun^{a*}, Lingyan Yang^{b*}, Lu Jin^a, Zhiwen Luo^c, Yan Zhang^d, Yanzhu Liu^e, Zhengru
5 Wang^d

6 ^a School of Building Services Science and Engineering, Xi'an University of Architecture and
7 Technology, 710000 Xi'an, China

8 ^b China Academy of Building Research, 100013 Beijing, China

9 ^c School of Construction Management and Engineering, University of Reading, RG6 6AY
10 Berkshire, United Kingdom

11 ^d Haomaichangan Green Energy Limited (Shandong), 261000 Weifang, China

12 ^e Jian Engineering Project Management Limited (Shandong), 255000 Zibo, China

13

14

15

16 ***Corresponding author:**

17 Dr. Tingting Sun, School of the Building Services Science and Engineering, Xi'an University
18 of Architecture and Technology, China

19 Email: suntt@xauat.edu.cn

20 Dr. Lingyan Yang, China Academy of Building Research, China

21 Email: yly8111@163.com

22 Nomenclature

BHEs	borehole heat exchangers
CP	circulation pump
GHS	ground heat storage
HP	heat pump
SCs	solar collectors
SAGSHPs	solar-assisted ground-source heat pumps
$CCOP$	coefficient of performance for compressor
$SCOP$	coefficient of performance for the system
F_{mec}	fraction of monthly heat contributed by heat extraction from core GHS
F_{mhp}	fraction of monthly heat contributed by the HP
F_{msc}	fraction of monthly heat contributed by SCs
Q_{hp}	heat produced by the HP
Q_{mr}	monthly heat injected into the core region of the GHS
Q_{msc}	monthly valid heat gain of solar collectors
Q_{mu}	monthly heat supplied to the user side
Q_{muec}	monthly heat contributed by heat extraction from the core GHS
Q_{muhp}	monthly heat contributed by the HP
Q_{musc}	monthly heat consumption of user side contributed by SCs
$R_{ec/r}$	ratio of heat extracted from core GHS to the heat recharged into it
$R_{et/r}$	ratio of total heat-extraction from the ground to heat injected into it
$R_{mr/v}$	month-averaged ratio of the heat injected into the ground to the valid heat gain of SCs
t_{a1}	water temperature at the top of water tank A
t_{b2}	water temperature at the bottom of water tank B
t_{sc1}	water temperature at the upper header of the SCs mounted on the Dwelling 3 roof
t_{w1}	temperature measured at the borehole wall of W1

23

24 **Abstract**

25 To maintain the energy quality with high temperature and reduce the energy loss of seasonal
26 heat-storage in solar-assisted ground-source heat pumps (SAGSHPs), a novel SAGSHP system
27 with the heat-cascading of borehole heat-exchangers was designed and its field-test was
28 conducted in this paper. The borehole heat-exchangers were divided into two regions: the core
29 region and the peripheral region. The core region can maintain a high temperature (e.g. 45 °C),
30 which is much higher than in previous studies, and the heat from this region can be used
31 directly, without the operation of a heat pump. The field-test was conducted in a community in
32 the province Shandong, China. The results indicate that a sufficient soil-temperature gradient
33 (the temperature is high in the core but low at the periphery) can be created and maintained.
34 The monthly averaged borehole-wall-temperature difference between the borehole heat-
35 exchangers (BHEs) at the core and the periphery can be as high as 30.1 °C. This means that
36 both cascaded heat-storage and heat-utilization can be realized. In addition, an average
37 performance of $CCOP=5.15$ and $SCOP=4.66$ can be achieved. Compared with previous studies,
38 despite the lower $CCOP$, a higher $SCOP$ can be attained, thanks to heat cascade storage and -
39 utilization. The novel approach described in this paper represents a viable alternative for space
40 heating in North China.

41

42 **Keywords:** Solar-assisted ground-source heat pump; Seasonal heat-storage; Heat cascade
43 utilization; Hybrid thermal system; Field testing;

44

45 **1 Introduction**

46 During the past decades, ground-source heat pumps, a well-known type of renewable energy
47 technology, have grown in popularity (Yuan et al., 2012; Luo et al., 2016). Because the
48 temperature of the ground-soil changes less than the air temperature, and the evaporation
49 temperature is higher for heating applications, and the condensation temperature is lower for
50 cooling, ground source heat-pumps can reach higher energy-efficiencies than conventional air-
51 source heat pumps (Sarbu et al., 2014). However, in heating-dominant buildings, the thermal
52 imbalance of the soil can reduce the heating performance in the long-term (You et al., 2018;
53 Fine et al., 2018; Li et at., 2018). To solve this problem, solar-assisted ground-source heat
54 pump (SAGSHP) systems, where solar collectors are combined with a ground-source heat-
55 pump, are used in heating-dominant buildings (Olsson, 1984; Andrew et al., 2003). A SAGSHP
56 system attempts to compensate the thermal imbalance of the ground soil and achieve a higher
57 performance coefficient for the system (*SCOP*) in the long run (Xi et al., 2011; Yang et al.,
58 2006). Furthermore, when seasonal heat-storage is added, solar collectors can be used
59 throughout the whole year by injecting the heat into the ground soil using borehole heat
60 exchangers (BHEs) even during non-heating seasons (Bauer et al., 2010). However, a
61 significant disadvantage of conventional SAGSHPs which use seasonal heat-storage, is that the
62 heat produced by solar collectors at a higher temperature (e.g. 50 °C or higher) is converted
63 into the heat stored in the ground heat storage (GHS), which has a much lower temperature,
64 e.g. 18 °C or lower (Liu et al., 2016). Thus, thermal energy quality is wasted.

65 Previously investigated SAGSHP systems normally use one of three strategies:

66 In the *first* strategy, the ground soil is used as heat source for the heat pump but not for solar
67 heat storage. The heat produced by solar collectors can be used for space heating directly or as
68 low temperature heat source for the heat pump together with the heat from BHEs. However,
69 the heat is not injected into the ground even if heating demand is satisfied. This means, some

70 heat is wasted, especially during non-heating seasons. Razavi et al. (2018) simulated a
71 SAGSHP system that uses this strategy with TRNSYS. The group showed that power
72 consumption could be reduced by 8.7% compared to a standalone ground-source heat pump.
73 Bi et al. (2004) conducted an experiment on a SAGSHP system using this strategy, and a *SCOP*
74 of 2.78 was reported.

75 In the *second* strategy, ground soil is not only used as heat source for the heat pump but also
76 for short-term heat storage. This means the solar collectors can be used during the heating
77 season. However, they are still idle during the non-heating seasons. Solar collectors and BHEs
78 can work alternately, simultaneously, or independently. In the alternating operating mode,
79 solar collectors operate during daytime, and the produced heat is injected *into* the ground soil,
80 and the ground-source heat-pump operates in the evening to extract heat *from* the ground (Yang
81 et al., 2015). According to the experimental study by Verma et al. (2017), the *SCOP* increased
82 by 23 % in this mode compared with a standalone ground-source heat-pump. In the
83 simultaneous operating mode, solar collectors and BHEs can be connected in series or parallel
84 with each other. Dai et al. (2015) reported that the *SCOP* reached 3.05 for series connection
85 and 2.83 for parallel connection in their experimental study. Si et al. (2014) conducted a
86 TRNSYS simulation in simultaneous mode and found that the soil temperature decreased by
87 0.8 °C after 10 years of operation, compared to 3.1 °C for a standalone ground-source heat-
88 pump. The independent working mode uses double U-tube BHEs (Cimmino and Eslami-Nejad,
89 2017; Shah et al., 2018). BHEs act as heat exchangers between the solar-collector loop and the
90 ground-source heat-pump loop as well as a short-term heat storage. Weeratunge et al. (2018)
91 optimized the system using CPLEX and reported a *SCOP* of 3.31 for the independent
92 connection.

93 In the *third* strategy, ground soil is used as heat source for both the heat pump and seasonal
94 heat-storage. A special characteristic of this operating strategy is that the solar collectors

95 continue to operate during the non-heating seasons, and *the heat is injected into the ground to*
96 increase the soil temperature (Stojanović and Akander, 2010). In other words, the solar
97 collectors contribute to the thermal balance not only because less heat is extracted from the
98 ground but also because more heat is *injected into it* throughout the year. Chen and Yang.
99 (2012) conducted a TRNSYS simulation using this strategy and found that the *SCOP* could be
100 improved by as much as 26.3 % compared to a standalone ground-source heat-pump. In
101 addition, the average ground-soil temperature increased by 0.21 °C each year instead of the
102 expected decrease, according the experimental study by Zhu et al. (2015).

103 The SAGSHP with the seasonal heat storage is commonly considered a reasonable and efficient
104 system. However, previous studies did not consider that the high-temperature heat produced
105 by solar collectors was stored and used at a much lower temperature, which wastes thermal
106 energy. In most studies, the heat that was produced by solar collectors was injected evenly into
107 the GHS, and the soil temperature was generally quite low, e.g. 18 °C or lower (Liu et al., 2016).
108 Therefore, the heat medium, which is used to extract heat from the GHS, must be delivered to
109 the evaporator of the heat pump to increase the temperature. This, however, means, the system
110 performance remains low. Previous studies show that the soil temperature cannot reach more
111 than 12 °C if only one or two BHEs are used in a SAGSHP system (Kjellsson et al., 2010;
112 Reda, 2015; Georgiev et al., 2018; Trillat-Berdal et al., 2006; Niemann and Schmitz, 2019).
113 Even if more BHEs were used, the soil temperature could barely exceed 20 °C when the BHEs
114 were connected in parallel (Emmi et al., 2015; Wang et al., 2010; Rad et al., 2013). Hesaraki
115 et al. (2015) recommended a system, where many groups of BHEs were connected in series
116 and the heat produced by solar collectors was injected into the GHS from the core to the
117 periphery. However, the heat that was extracted from the GHS was generally used as a heat
118 source for the heat pump, and heat cascade utilization was not discussed. Another similar
119 configuration of a GHS was used in Okotoks, Canada (Pinel et al., 2011; Xu et al., 2014;

120 Kandiah and Lightstone, 2016). The system had no heat pump, which means the heat could not
121 be fully used when the soil temperature fell to below a certain level. Wang et al. (2012)
122 performed a TRNSYS simulation, connecting 8/9 BHEs in series. The results showed that the
123 peak soil temperature can reach 29 °C, 25 years later. However, the position-relation between
124 BHEs and heat cascade utilization was not discussed. Furthermore, the extracted heat was also
125 used only as a *low-temperature* heat-source for the heat pump.

126 To maintain the energy quality **with higher temperature**, heat-cascading is considered in this
127 study of a promising novel SAGSHP system. The BHEs were divided into two regions: the
128 core region and the peripheral region. Solar heat is injected into the core region, and a soil
129 temperature gradient, which is higher in the core and lower at the periphery, is created (see
130 details in Section 2.2). This is very different from the conventional uniform temperature-profile.
131 The biggest benefit is that heat cascade storage and utilization can be implemented. More
132 specifically, the heat, which was extracted from the peripheral region at a lower temperature
133 (e.g. 20 °C), was used as a low-temperature heat source for the heat pump. In addition, the heat,
134 which was extracted from the core region at a higher temperature (e.g. 45 °C), was used for
135 space heating, directly. The system construction and operating principle are described in this
136 paper in detail, and a real-world project of this novel hybrid system for space heating is tested.
137 Finally, the system performance is evaluated in the subsequent sections.

138 **2 Description of the project background and the hybrid system**

139 **2.1 Real-world project background**

140 The targeted community, Datangfuyuan, is located in the City Gaomi (long.119°26'E-
141 120°01'E, lat. 36°09'N~36°41'N, alt. +7.5~+109.4m, Fig. 1) in the province Shandong, China.
142 A detailed description of the local climate is shown in Tab. 1 (Xu et al, 2012a). The community
143 consists of 9 dwellings – each has 6 floors. The total floor area is 22342 m² with a total designed

144 heating load of 554 kW. The hybrid system was used for space heating only. The terminal was
 145 a low-temperature hot-water radiant floor-heating system.



146
 147 Fig. 1. Geographic location of Gaomi City, which is located in a cold climate zone in China

148 Table 1 Detailed description of the climatic conditions


Item	Value/Description
Weather station (nearest to Gaomi)	Weifang (long.119°11'E, lat. 36°45', alt. +22.2m)
Outdoor heating design temperature in winter ^a	-7.0 °C
Average temperature during the heating season	-0.3 °C
Original soil-temperature (deep)	14.8 °C
Total horizontal solar radiation	4613.6 MJ/(m ² ·y)
Sunshine percentage in winter	58 %
Heating degree days at 18 °C indoor	2799 °C·d

149 a: This concept is defined by Chinese Design code for heating ventilation and air
 150 conditioning of civil buildings. It is used to decide the scale of pace heating system

151
 152 **2.2 System description**

153 The hybrid system (Fig. 2) consists of the following key-components – heat-pump unit, solar
 154 collectors, BHEs, water tanks, circulation pumps, heat exchanger, and a low-temperature hot-
 155 water radiant floor-heating system. One heat-pump set, with a nominal heating capacity of
 156 352.3 kW and a heating rated power input of 75.7 kW, was employed. Evacuated-tube solar-


157 collectors were used because of their excellent anti-freeze capabilities. 212 sets of solar
 158 collectors (diameter: 58 mm, length: 1800 mm, tubes: 50), filled with ethylene glycol, were
 159 mounted on the roofs of the dwellings. They faced south and were tilted at an angle of 36 °.
 160 Two water tanks, with the same volume (125 m³), were used as a thermal buffer as well as
 161 short-term heat-storage. By connecting the bottom of the water tank A with the top of water
 162 tank B, a thermal stratification was created.



163
 164 Fig. 2. Schematic of the novel hybrid-system (HP: heat pump, CP: circulation pump, SCs:
 165 solar collectors, BHEs: borehole heat-exchangers)

166 In total, 150 single U-pipe BHEs were installed. The borehole depth was 75 m, and the diameter
 167 is 150 mm. Thus, the total pipe-length in the BHEs was 22,500 m. The borehole pitches
 168 between the BHEs are shown in Fig. 3. These BHEs were divided into 2 groups, the core region
 169 and the peripheral region. Solar heat was injected into the BHEs of the core region but not into
 170 the peripheral region. In the core region, 76 BHEs were organized into 19 loops. There were 4
 171 BHEs in each loop, which were connected in series. The heat medium flew through the BHE
 172 near the core first, then, sequentially, to the other three BHEs that were located further from
 173 the core, during the injection of heat into the ground - see Fig. 3. When heat was extracted from
 174 the ground, the heat-medium flow-direction could be reversed using the on/off remote-

175 controlled valves V_{a1} - V_{a6} - see Fig. 4. This design creates a temperature gradient, with a higher
 176 temperature in the core and a lower one at the periphery. This also enables heat cascade storage
 177 and utilization. During the heating season, the heat, which was extracted from BHEs in the core
 178 region, could be used directly for space heating without the heat pump if the temperature was
 179 high enough. Even when the temperature was not high enough for direct heating, the BHEs in
 180 the core region were connected to the condenser of the heat pump via water tanks (instead of
 181 the evaporator) - see Fig. 4. This makes better use of the heat at higher temperature, e.g. at
 182 45 °C, compared to the heat from peripheral region that could be at only 20 °C. There were 74
 183 BHEs in the peripheral region. These were connected in parallel with each other and with the
 184 evaporator of the heat pump, which was used as a low-temperature heat-source. Furthermore,
 185 the BHEs in the core region were not used as low-temperature heat-sources for the heat pump.
 186 This way it was possible to maintain a higher temperature in the core and contribute to a
 187 temperature gradient that points from the periphery to the core.



188
 189 Fig. 3. Arrangement and division of BHEs for GHS. The transition of colour from red to blue
 190 represents a temperature gradient from high to low. Pink wells (W1~W5) mark the
 191 measurement points for the borehole-wall temperature.




Fig. 4. Schematic of the hybrid system

(SC: solar collector, GHS: ground heat storage)

On the top of the GHS sits an insulation board, which is made of extruded poly styrene (XPS) and a moisture barrier made of high-density polyethylene (HDPE). Prior to the project design, thermal-response tests were performed. The tests were carried out from 31 Jul to 2 Aug 2014, with inlet and outlet temperatures of 27.4 °C and 24 °C, respectively. The results were: the initial temperature in deep ground, without disturbance, was $t_i=14.8$ °C, thermal conductivity was $\lambda=2.176$ W/m·K, the specific heat capacity was $C_p=1.39$ MJ/m³, and heat flux was $q=40.7$ W/m.

2.3 Operating modes

The system operates in different modes, depending on climate and heating demand (see Tab. 2). These can be described as follows:

Non-heating mode: During non-heating season, the solar-collector side (see Fig. 4) operates, when solar radiation is high. The antifreeze-liquid in the solar collectors captures heat and delivers it to water tanks via a heat exchanger and the circulation pumps, P1 and P2. Heat, which was conserved in the water tanks was injected into the core region of the GHS, driven

209 by P3. The heat pump and the user side were switched-off in this mode because there is no
210 heating demand.

211 **Heating mode:** During heating season, heat produced by solar collectors could be used directly
212 for space heating. Heat, which was extracted from the BHEs in the core region, were a second
213 support option if the solar collectors alone were not sufficient to meet the heating demand. The
214 heat pump was turned on when both, solar collectors and the heat extracted from the core
215 region, were not sufficient.

216 **2.4 Control strategy**

217 The control strategy is summarized in Tab. 2.

218 **Solar-collector side:** The on/off control of the solar-collector side was based on the monitors
219 for the water temperature at the top of the water tank A (t_{a1}) and the upper header of the solar
220 collectors mounted on the Dwelling 3 roof (t_{sc1}). As shown in Tab. 2, circulation pumps (P1
221 and P2) begin to operate when $t_{sc1} > 90$ °C. The operation continues until $t_{sc1} < t_{a1} + 10$ °C. The
222 control parameters were identical for the heating and non-heating seasons.

223 **User side:** The user side operates intermittently during heating-season and was controlled by
224 skilled engineers. The first two heating seasons for this project were from 2 Nov 2015 to 22
225 Mar 2016, and from 11 Nov 2016 to 18 Mar 2017.

226 **Core GHS side:** There are two operating conditions for the core GHS side: *injecting heat* into
227 the GHS during the non-heating season and *extracting* heat from it during heating season (see
228 Tab. 2). Heat injection starts for $t_{a1} > t_{w1} + 15$ °C, where t_{w1} is the temperature measured at the
229 borehole wall of W1 - see Fig. 3. Heat injection lasts until $t_{a1} < t_{w1} + 10$ °C, while heat extraction
230 only takes place during the heating season. It starts if the two conditions are satisfied at the
231 same time: $t_{w1} > t_{b2} + 10$ °C and $t_{a1} < 50$ °C, where t_{b2} is the water temperature at the bottom of
232 water tank B. When the core GHS side operates in injection mode, the valves V_{a2} , V_{a3} , and V_{a4}
233 are closed, while the valves V_{a1} , V_{a5} , and V_{a6} are open - see Fig. 4. Water is pumped from the

234 top of the water tank A to the BHEs in the core GHS, which is shown in red in Fig 3, via the
 235 water manifold A. After the heat exchange, water was collected by the water manifold B and
 236 returned to the bottom of water tank B. On the other hand, when operating in extraction mode,
 237 the valves V_{a2} , V_{a3} , and V_{a4} were open, while the valves V_{a1} , V_{a5} , and V_{a6} were closed. Then,
 238 the direction of the water flow reversed.

239 **Heat pump and peripheral GHS side:** The heat-pump operates only when the two conditions
 240 were satisfied simultaneously, i.e., the user side was operating and $t_{a1} < 50$ °C. If the heat pump
 241 works, valve V_{b1} was closed, and valves V_{b2} and V_{b3} were opened. Otherwise the opposite
 242 occurred.

243 Table 2 Operating modes and control strategies

Season	User side	Solar collector side	Core GHS side	Heat pump & peripheral GHS side
Non-heating	OFF	Solar heat is used for heat injection to the ground.	Heat is injected into the ground. Open valves: V_{a1} , V_{a5} , V_{a6} ; Close valves: V_{a2} , V_{a3} , V_{a4} .	OFF
Control strategy		If $t_{sc1} > 90$ °C, turn on pumps P1, P2. If $t_{sc1} < t_{a1} + 10$, turn off pumps P1, P2.	If $t_{a1} > t_{w1} + 15$ °C, turn on pump P3. If $t_{a1} < t_{w1} + 10$ °C, turn off pump P3.	
Heating	Operates intermittently	Valid heat gain is used for space heating.	Heat is extracted from the ground. Close valves: V_{a1} , V_{a5} , V_{a6} ; Open valves: V_{a2} , V_{a3} , V_{a4} .	Only operates when the heat from SCs and core GHS cannot meet the heating demand.
Control strategy	Controlled by skilled engineers.	The same as non-heating season.	If $t_{w1} > t_{b2} + 10$ °C and $t_{a1} < 50$ °C, turn on pump P3. Otherwise, turn off pump P3.	If the user side operates and $t_{a1} < 50$ °C, turn on the heat pump; turn on pump P5; open valves V_{b2} , V_{b3} ; close valve V_{b1} . Otherwise the opposite is true.

244

245 **3 Methods**

246 **3.1 Data collection**

247 The data-collection system includes the temperature-measurement system, heat-measuring
248 system, and electricity-measurement system. The indoor temperature of four sample flats,
249 outdoor temperature, soil temperature at the borehole wall, water temperature at the top of
250 water tank A and the bottom of water tank B, and the water temperature at the top header of
251 the solar collectors were measured. To measure the borehole wall temperatures, sensors were
252 buried in suitable boreholes (W1 ~ W5), which are highlighted in pink in Fig. 3. As reported
253 in the literature (Niemann and Schmitz, 2019; Xi et al., 2017), the borehole-wall temperature-
254 change in the vertical direction was small and could be ignored. Thus, only one measurement
255 point was set for each borehole, at a depth of 30m. In addition, the heat meter H_{sc} was used to
256 measure the heat flux produced by the solar collectors. The heat meters H_r and H_e , were used
257 to measure the heat injected into and extracted from the BHEs in the core region. The heat
258 meters H_{wt} and H_{hp} , were used to measure the heat supplied by the water tanks and the heat
259 produced by the heat-pump condenser. And the heat meter H_u was used to measure the heat
260 supplied to the user side - see Fig. 4. Two electricity meters were used to measure the electric
261 input. One was used to measure electric input for the whole system, including all pumps and
262 the heat pump. The other one was used to measure the electric input for the heat pump
263 separately. Detailed information of the used devices is provided in Tab. 3. All data were logged
264 within an interval of 30 min.

265 **3.2 Uncertainty analysis**

266 The uncertainty analysis in the field test includes the error estimation for both measured and
267 calculated parameters. The relative errors of the measured and calculated parameters can be
268 obtained using the following equations (Dai et al., 2015):

$$269 \quad \Delta X_i / X_i = \lambda_x \cdot L_x / X_i \quad (1)$$

270
$$\Delta Y_i/Y_i = \sqrt{\sum_1^n \left(\frac{\partial Y_i}{\partial X_i} \lambda_x \cdot L_x \right)^2} / Y_i \quad (2)$$

271 where L_x is the upper limit of the measuring range, λ_x is the accuracy according to the
 272 manufacturer, X_i is the value of a measured parameter, Y_i is a function of a series of measured
 273 independent variables. The relative errors of the main parameters in the field test are shown
 274 in Tab. 4.

275 Table 3 Specifications of the used measurement devices

Device	Type	Measurement range	Accuracy
Temperature sensor	WZP-230PT100	0-100 °C	$\pm(0.15+0.002 t)$ °C
Heat meter	CRL-G(DN80,65)	/	$3+4\Delta t_{\min}/\Delta t+0.02q_p/q$
Electricity meter	400/5	/	± 1 %

277 Table 4 Uncertainty of the main parameters


Parameters	Unit	Relative uncertainty (%)	Parameters	Relative uncertainty (%)
Outdoor temperature	°C	0.85	F_{mec}	6.55
Indoor temperature	°C	0.80	F_{mhp}	7.15
borehole wall temperature	°C	0.47	F_{msc}	8.12
Heat at solar side	kW·h	4.25	$R_{ec/r}$	6.22
Heat at core GHS side (injected)	kW·h	3.64	$R_{mr/v}$	6.21
Heat at core GHS side (extracted)	kW·h	5.05	$R_{et/r}$	6.57
Heat supplied to user side	kW·h	5.42	$CCOP$	5.78
Heat produced by heat pump	kW·h	5.42	$SCOP$	4.61
Heat from water tank to user side	kW·h	5.42		
power consumption of heat pump & circulation pumps	kW·h	1		
power consumption of heat pump	kW·h	2		

278
 279 **4 Test results and performance analysis**

280 **4.1 Indoor- and outdoor- temperature during the heating season**

281 The heating season started from 11 Nov 2016, but the indoor temperature records were from
 282 10th of Dec 2016. As shown in Fig. 5, most of the day-averaged indoor temperatures met the

283 Chinese standard (not lower than 16 °C) (Xu, et al., 2012b). The few exceptions were
 284 infrequent, and they may have been caused by opened windows for example since the
 285 occupants were not instructed to follow any special procedures. This means the space-heating
 286 requirements were adequately met using this hybrid system.




287
 288 Fig. 5. Day-averaged indoor and outdoor temperature during the heating season


289 **4.2 Monthly supplied heat to the user during the heating season**

290 As illustrated in Fig. 6 (a), the monthly heat supplied to the user, Q_{mu} , during the first heating
 291 season (Nov 2015 ~ Mar 2016), varied parabolically. The peak value of 65.08 MW·h occurred
 292 on Jan 2016 with the lowest value (29.97 MW·h) on Nov 2015. While the trend of Q_{mu} during
 293 the second heating-season (Nov 2016 ~ Mar 2017) was similar to the first one, the absolute
 294 values were much higher due to a higher occupancy rate. The highest Q_{mu} occurred on Jan 2017
 295 when 158.87 MW·h were reached, while the lowest value was recorded on Nov 2016 (53.68
 296 MW·h). The total heat supplied to the user side for the two heating seasons were, respectively,
 297 229.97 MW·h and 580.63 MW·h. According to Fig. 6, the monthly heat, which was supplied
 298 to the user by solar collectors (Q_{musc}), showed little difference for the two heating seasons in
 299 the respective months. Yet, according to Fig. 7, their fractions (F_{msc}) for the first heating season
 300 were vastly higher than for the second. This is because the capacity of the solar collectors did
 301 not increase with increased heating demand, i.e., a lower Q_{mu} caused a higher F_{msc} . On the other
 302 hand, a higher heating demand means a larger contribution by the heat pump, independent of

303 Q_{muhp} or F_{mhp} - see Figs 6 and 7. Furthermore, the system was able to work with a higher $SCOP$
304 (= the heat supplied to the user side by the hybrid system divided by the total electricity
305 consumed by the system including circulation pumps and heat pump) when the community had
306 a lower occupancy rate. The contribution of the heat extracted from the core GHS also
307 increased both in value (Q_{musc}) and fraction (F_{mhp}) for the second heating season compared to
308 the first one. As much as 2.87 MW·h and 0.36 MW·h of heat were extracted from the core GHS
309 on Nov and Dec during the first heating season. The values for the second heating season were
310 15.20 MW·h and 40.80 MW·h. In addition, 7.00 MW·h and 0.25 MW·h heat were extracted
311 from the core GHS on Jan and Feb during the second heating season. This occurred because
312 heat accumulation had not been so large for the first heating season. According to Fig. 7, due
313 to the higher soil temperature at the beginning of the second heating season, the contribution
314 fractions for heat extraction from core GHS (F_{mec}) on Nov and Dec 2016 were much higher
315 than for later months. Heat extraction from core GHS mainly occurred on Nov and Dec 2016,
316 which accounted for 88.5 % of the total of the whole heating season.



317
318
319 Fig. 6. Monthly heat-consumption on user side and its composition



320


321

322 Fig. 7. Fractions of contributions for heat from the heat pump, solar collectors, and extracted
 323 from core GHS

324 **4.3 CCOP during the heating season**

325 Average *CCOP* (=the heat produced by heat pump divided by the electricity consumed by the
 326 heat-pump compressor) during different periods of the second heating season are depicted in
 327 Fig. 8. The highest average *CCOP* of 6.05 occurred in the earliest period in the heating season.
 328 A downward trend can also be identified using this chart. The lowest value of 4.72 occurred in
 329 the last period of the heating season. This is because the soil temperature reached the peak
 330 value at the start of the heating season after as many as 8 months of heat injection. The soil
 331 temperature gradually decreased as heat was continually extracted from the ground and
 332 diffused to the surrounding soil. Interestingly, an increase of *CCOP* was observed for the period
 333 from 16 Feb to 26 Feb - see Fig. 8. This is because the heat production by the heat pump (Q_{hp})
 334 during this period was at a low level. Because a lower Q_{hp} caused less heat-exchange demand
 335 between the heat medium in the BHEs and the surrounding soil, a lower temperature difference
 336 was needed. Hence, the inlet water temperature for the heat-pump evaporator increases.
 337 Furthermore, thanks to reduced heat extraction from the BHEs, the soil temperature near the
 338 BHEs could recover faster. The temperature recovery also increases the temperature of the
 339 water supplied to the evaporator. For these two reasons, a higher *CCOP* was achieved. A

340 similar trend can be found for the period 7 Jan to 17 Jan. In other words, $CCOP$ decreased
 341 faster, when Q_{hp} was higher. Moreover, when Q_{hp} was lower, $CCOP$ reduced slower or even
 342 increased slightly.



343


344 Fig. 8. The average values of $CCOP$ and Q_{hp} during different periods

345 4.4 Valid heat gain of solar collectors and its destination

346 Fig. 9 (a) shows the monthly valid heat gain of solar collectors (Q_{msc}) during a calendar year in
 347 2016. Q_{msc} on June was the highest for the whole year, with 99.17 MW·h. The values for May
 348 and July were second and third, with about 95 MW·h. Unfortunately, Q_{msc} was generally low
 349 in the months during heating season. January and December had the lowest Q_{msc} of the year,
 350 with 36.34 MW·h and 37.14 MW·h, respectively. There are two reasons for this phenomenon.
 351 The first one is that the outdoor temperature was low during these months, which reduced the
 352 efficiency of the solar collectors. The second reason is that, the subsolar point was far from the
 353 targeted city during heating season. As a result, less solar radiation reached the solar collectors.
 354 These two reasons are applicable to all cities in north China. Thus, the variations of the valid
 355 heat gain of solar collectors for different cities are similar. Considering this, a seasonal heat-
 356 storage is indispensable to make full use of solar collectors for the entire year. The monthly
 357 heat injected into the core GHS (Q_{mr}) is shown in yellow in Fig. 9 (a). The month-averaged
 358 ratio of the heat injected into the ground to the valid heat gain of solar collectors ($R_{mr/s}$) is

359 shown in purple. For most of the non-heating months, $R_{mr/v}$ exceeded 90 %. An exception was
 360 on October with 88 %. Heat was rarely injected into the ground during the heating season, so
 361 that it could be efficiently utilized for space heating directly.

362 As shown in Fig. 9 (b), the total valid heat gain of the solar collectors for the year was 838.99
 363 MW·h. A fraction of 70 % (528.63 MW·h) was injected into the core GHS, and a fraction of
 364 25 % (211.28 MW·h) was used directly for space heating. The remaining 5 % (45.08 MW·h)
 365 were lost to ambient air.



366 a Monthly valid heat-gain of solar collectors and its injection in the ground


367 b Percentages of different destinations for valid heat gain of solar collectors

368
 369
 370 Fig. 9. Valid heat gain of solar collectors and its destination

371 4.5 Heat injected into (and extracted from) core GHS

372
 373 The ratio of heat extracted from core GHS to the heat injected into it ($R_{ec/r}$) is a primary
 374 parameter to evaluate the performance of both heat cascade utilization and seasonal heat
 375 storage. A higher $R_{ec/r}$ means that the heat cascade utilization and seasonal heat storage are
 376 more efficient. The monthly heat injected and extracted during the period of July 2015 to May

377 2017 is shown in Fig.10. The period before Feb 2016 is defined as the first recharge/extraction
 378 cycle, while the period from Mar 2016 to Feb 2017 is defined as the second recharge/extraction
 379 cycle. During the first recharge/extraction cycle, little heat was extracted from core GHS, and
 380 $R_{ec/r}$ was very low, less than 1 %. The maximum monthly heat, which was extracted from core
 381 GHS was only 2.87 MW·h. The reasons for this were given in Section 4.2. For the second
 382 recharge/extraction cycle, the monthly heat, which was extracted from core GHS, increased
 383 significantly (to 15.20 MW·h, 40.80 MW·h and 7.00 MW·h in Nov, Dec 2016, and Jan 2017).
 384 $R_{ec/r}$ increased to 10.86 % as a result of substantial heat accumulation in the GHS. This is
 385 considered to be a sufficiently good number. As the heat accumulation in the core GHS
 386 continued, a higher $R_{ec/r}$ could be expected because an upward trend for the borehole wall
 387 temperature was observed in the core region, when the first and the second recharge/extraction
 388 cycle (see Section 4.6) were compared.




389 Fig. 10. Monthly heat extracted (MW·h) from core GHS

391 4.6 Variation of borehole wall temperatures

392 The variation of the month-averaged borehole wall temperatures in the respective BHEs (Fig.
 393 3) is shown in Fig. 11. A significant temperature-gradient, which was higher in the core and
 394 lower at the periphery, can be seen. The temperature difference between W1(at the core) and

395 W5 (at the periphery) increased during the second recharge/extraction cycle compared with the
396 first one, which increased from 19.4 °C in Jun 2015 to 30.1 °C in Nov 2017. These results are
397 very promising for heat cascade storage and utilization. According to Fig. 11, the peak value
398 of W1 reached 56.6 °C in Oct 2016. As measured, the outlet medium temperature of the
399 extracted heat from the core GHS, can reach 43.4 °C at the start of the second heating season.
400 This temperature was much higher than the one reported in other studies, for example, 15.2 °C
401 in Li et al. (2018). It exceeded the maximum recommended inlet water temperature (20 °C) for
402 the heat pump evaporator in heating mode according to the product specifications (Menergy,
403 2019). Thus, the water, which extracted heat from the core ground heat-storage, was pumped
404 to the user directly or to the condenser of the heat pump. Heat could be utilized at higher
405 temperature using this approach. On the other hand, the water that extracts heat from peripheral
406 BHEs can reach the evaporator of the heat pump and be used as heat source. In other words,
407 cascaded heat utilization was realized successfully.

408 In addition, as seen in Fig. 11, the highest month-averaged temperature of W1~W4, for the core
409 region, sharply increased compared to the first and the second recharge/extraction cycle. The
410 average growth was 9.9 °C, while the highest monthly-averaged temperature in W5 at the
411 periphery increased by 5.9 °C. The temperature increase in the core region suggests a larger
412 potential of energy usage at the higher temperature.



413


414 Fig. 11. Variation of the borehole-wall temperatures in the borehole heat exchangers W1~W5

415 **4.7 Energy balance of the hybrid system**

416 To learn more about the performance of the hybrid system, the energy-flow between the
 417 different components in the second recharge/extraction cycle are shown in Fig. 12. The total
 418 valid heat gain of the solar collectors was measured to be 838.99 MW·h, of which 582.63 MW·h
 419 was injected into the core GHS. Simultaneously, 63.25 MW·h was extracted from core GHS,
 420 and 266.00 MW·h was supplied to the user side from the water tanks. All the above values
 421 were measured using heat meters. According to the energy-conservation principle, a total heat-
 422 loss of 53.61 MW·h took place. For the heat pump, the heat meter measured a heat flow of
 423 306.10 MW·h at the condenser side, and the power meter showed 59.39 MW·h of electric input,
 424 which means that the average $CCOP$ was 5.15 ($306.10/59.39=5.15$). Furthermore, as much as
 425 246.71 MW·h of heat was extracted from the BHEs in the peripheral region. The ratio of total
 426 heat-extraction from the ground to heat injected into it, $R_{et/r}$, was 53.2 %
 427 ($((63.25+246.71)/582.63=53.2\%)$). On the other hand, the ratio of heat extracted from core GHS
 428 to the heat injected into the ground, $R_{ec/r}$, was 10.86 % - see Section 4.5. Thus, the heat, which
 429 was extracted from ground and used at *higher* temperature, divided by heat extracted from
 430 ground and used at *lower* temperature, was about 1/4 ($63.25/246.71$). The total heat supplied


431 to the user side was 580.63 MW·h. Of this, 306.10 MW·h was produced by the heat-pump
432 condenser, which accounted for 52.7 % $(306.10/580.63)$. 63.25MW·h, which accounted for
433 10.9 % $(63.25/580.63)$, was due to the heat extraction from the core GHS. The remainder of
434 the heat, about 36.4 % $(1-52.7\% -10.9\%)$, came from the solar collectors directly. Three
435 measured heat flows were then compared: the heat flow of the user side, the heat flow produced
436 by the heat pump, and the heat flow supplied by the water tanks to the user side. An error of
437 1.5 % $((580.63-266.00-306.10)/580.63=1.5\%)$ was found. It falls within the error described in
438 Section 3.2.

439 The total electricity consumption of the system in the second recharge/extraction cycle was
440 124.57 MW·h $(65.18\text{ MW·h}+59.39\text{ MW·h})$. Considering that the total heat supplied to the user
441 side was 580.63 MW·h, the *SCOP* during the second recharge/extraction cycle was 4.66
442 $(580.63/124.57)$. The circulation pumps consumed 65.18 MW·h electricity, which was more
443 than half of the total. Fig. 13 shows the percentage of the monthly electricity consumption by
444 the heat pump and circulation pumps. 52.3 % $(65.18/124.57)$ of the total electricity was
445 consumed by circulation pumps. 23.8 % $(29.68/124.57)$ was consumed during non-heating
446 seasons, while 28.5 % $(52.3\% - 23.8\%)$ was consumed during the heating season. The heat
447 pump alone consumed 47.7 % $(59.39/124.57)$. Fig. 6 and Fig. 13 show the months, when the
448 heat pump contributed more thermal energy, and it likely consumed more electricity. In Dec
449 2016 and Feb. 2017, however, the heat produced by the heat pump was almost the same, while
450 the electricity consumption by the heat pump was much higher in Feb. 2017. This is because
451 the *CCOP* decreased as the heating season continued. The results for the circulation pumps and
452 the heat pump confirm that decreasing the power consumption of the circulation pumps is as
453 important as finding ways to reduce the power consumed by the heat pump.



454

455 Fig. 12. Energy diagram for the system during the second recharge/extraction cycle



456

457 Fig. 13. Electricity input distribution of the system during the second recharge/extraction

458 cycle (CP: circulation pump, HP: heat pump)

459 **5 Discussion**

460 **5.1 SCOP, CCOP, $R_{ec/r}$, and $R_{et/r}$**

461 *SCOP* represents the overall energy efficiency of the whole hybrid system. A higher *SCOP*
 462 number means that less power is consumed by the system. *CCOP*, on the other hand, is used
 463 to characterize the energy efficiency of the heat pump alone. It is not necessarily true that the
 464 hybrid system is capable of reaching a high *SCOP* when the *CCOP* is high. $R_{ec/r}$, the ratio of
 465 heat extracted from core GHS to the heat injected into the ground, is used to characterize heat

466 cascade utilization. A higher $R_{ec/r}$ indicates that a larger proportion of the injected heat is
467 extracted and used at a high temperature. The last parameter $R_{et/r}$, which is the ratio of the total
468 heat extraction from the ground to the heat injected into it, reflects the energy balance of input
469 and output with respect to the GHS. More heat is injected into the GHS than extracted if $R_{et/r}$
470 < 1 , which means the trend of the soil temperature in the GHS is upward. Otherwise, the trend
471 is downward. For this project, a $R_{et/r}$ of 53.2 % was obtained. The upward trend of the soil
472 temperature in the GHS is shown in Fig. 11.

473 5.2 Comparison with previous studies

474 The greatest improvement for this hybrid system, compared to previous systems, is the
475 realization of both heat cascade storage and utilization. In most previous studies, the heat
476 produced by solar collectors was evenly injected into the ground, which caused only a small
477 temperature difference between the core and the periphery of the GHS. In the few studies,
478 where a soil temperature gradient was created, the extracted heat from the ground was generally
479 used as heat source for the heat pump, which led to lower system performance (Hesaraki et al.,
480 2015; Wang et al., 2012). In the present study, the test results indicate that the sufficient soil
481 temperature gradient, which is high at the core and low at the periphery, can be created and
482 maintained. About 20 % of the extracted heat from the GHS was used at high temperature and
483 not as heat source for the heat pump. As a result, a higher $SCOP$ of 4.66 was reached, compared
484 with 3.42 in Wang et al. (2012). Even the $CCOP$ for the heat pump is lower than for previous
485 research: 5.15 VS 5.4 (Wang et al., 2012). Despite the lower $CCOP$ for the heat pump, a higher
486 $SCOP$ was attained, thanks to heat cascade storage and utilization.

487 5.3 Limitations and suggestions for future studies

488 While this new system has been described in detail and was field-tested, which confirmed that
489 it is energy efficient, it should be noted that it is subject to certain limitations and uncertainties:

490 1) The initial investment costs are high because of the solar-collector purchase and borehole

491 drilling. The investigated project was possible and successful due to a subsidy from the
492 government, which supports renewable energy for space heating. This subsidy, however, is
493 only available in selected regions. Therefore, it is generally important to reduce system costs.
494 2) It is a complex system that consists of many components. Optimally designed components
495 are essential to ensure safe operation, high efficiency, and affordability. The hybrid system
496 may be used in different building types and various climates. However, it is difficult to create
497 a design criterium that would suit every building and all climatic zones. 3) Just as the system
498 design, both control strategy and operating conditions need to be optimized further to improve
499 energy efficiency and reduce cost.

500 **6 Conclusions**

501 [To maintain the energy quality with high temperature and reduce the energy loss of seasonal](#)
502 [heat-storage, a novel SAGSHP system considering heat cascade utilization was introduced and](#)
503 [investigated in this study.](#) The installation and field test of the system were conducted in the
504 community Datangfuyuan, China. The system performance was analysed, and the main
505 conclusions can be summarized as follows:

506 i) The field test shows that the day-averaged indoor temperature can meet the Chinese standard
507 (not fall below 16 °C), which shows that the system could satisfy the heating demand
508 successfully.

509 ii) A high core-temperature and low temperature at the periphery could be implemented and
510 maintained. The month-averaged borehole wall temperature difference between the BHEs, at
511 the core and the periphery, was as high as 30.1 °C. This indicates that heat cascade storage and
512 utilization is practically possible. In addition, the highest month-averaged temperature of the
513 borehole wall in the core increased by 9.9 °C during the second recharge/extraction cycle,
514 compared to the first recharge/extraction cycle. The upward trend of the soil temperature in the

515 core region suggests that higher heat-extraction from the core region may be possible in the
516 future.

517 iii) The energy (heat and electricity) balance for the system throughout the second
518 recharge/extraction cycle yields the following performance parameters: $SCOP=4.66$,
519 $CCOP=5.15$. It also shows that 10.9 % of the total heat supplied to the user side comes from
520 the heat extraction from the core region of the GHS. 36.4 % was supplied directly from solar
521 collectors and 52.7 % from the heat pump. In addition, $R_{et/r}=53.2$ % and $R_{ec/r}=10.9$ % were
522 obtained for the second recharge/extraction cycle, which shows that more heat was injected
523 into the GHS than extracted. Moreover, the heat, which was extracted from the ground and
524 used at *high* temperature, divided by the heat extracted from the ground and used at *low*
525 temperature, was about 1/4.

526 **Acknowledgement**

527 This research was supported by the National Key Basic Research Program for Youth (No.
528 2016YFC0207800), the National Natural Science Foundation of China (No. 51408457), and
529 the State Scholarship Fund awarded by China Scholarship Council (No. 201807835013).

530 **References**

531 Andrew, D., Chiason, P.E., Cen, Y., 2003. Assessment of the viability of hybrid geothermal
532 heat pump systems with solar thermal collectors, ASHRAE Trans. 109, 487-500.

533 Bauer, D., Marx, R., Nußbicker-Lux, J., Ochs, F., Heidemann, W., Muller-Steinhagen, H.,
534 2010. German central solar heating plants with seasonal heat storage, Sol. Energy 84,
535 612-623.

536 Bi, Y.H., Guo, T., Zhang, L., Chen, L., 2004. Solar and ground source heat-pump system,
537 Appl. Energy 78, 231-245.

538 Chen, X., Yang, H., 2012. Performance analysis of a proposed solar assisted ground coupled
539 heat pump system, Appl. Energy 97, 888-896.

540 Cimmino, M., Eslami-Nejad, P., 2017. A simulation model for solar assisted shallow ground
541 heat exchangers in series arrangement, *Energy Build.* 157, 227-246.

542 Dai, L., Li, S., DuanMu, L., Li, X., Shang, Y., Dong, M., 2015. Experimental performance
543 analysis of a solar assisted ground source heat pump system under different heating
544 operation modes, *Appl. Therm. Eng.* 75, 325-333.

545 Emmi, G., Zarrella, A., Carli, M. D., Galgaro, A., 2015. An analysis of solar assisted ground
546 source heat pumps in cold climates, *Energy Convers. Manage.* 106, 660-675.

547 Fine, J.P., Nguyen, H.V., Friedman, J., Leong, W.H., Dworkin, S.B., 2018. A simplified
548 ground thermal response model for analysing solar-assisted ground source heat pump
549 systems, *Energy Convers. Manage.* 165, 276-290.

550 Georgiev, A., Popov, R., Toshkov, E., 2018. Investigation of a hybrid system with ground
551 source heat pump and solar collectors: Charging of thermal storages and space heating,
552 *Renewable Energy.*

553 Hesarakı, A., Holmberg, S., Haghghat, F., 2015. Seasonal thermal energy storage with heat
554 pumps and low temperatures in building projects—A comparative review, *Renew.*
555 *Sustain. Energy Rev.* 43, 1199-1213.

556 Kandiah, P., Lightstone, M., 2016. Modelling of the thermal performance of a borehole field
557 containing a large buried tank, *Geothermics* 60, 94-104.

558 Kjellsson, E., Hellström, G., Perers, B., 2010. Optimization of systems with the combination
559 of ground-source heat pump and solar collectors in dwellings, *Energy* 35, 2667-2673.

560 Li, H., Xu, W., Yu, Z., Wu, J., Yu, Z., 2018. Discussion of a combined solar thermal and
561 ground source heat pump system operation strategy for office heating, *Energy Build.*
562 162, 42-53.

563 Liu, L., Zhu, N., Zhao, J., 2016. Thermal equilibrium research of solar seasonal storage
564 system coupling with ground-source heat pump, *Energy* 99, 83-90.

565 Luo, J., Rohn, J., Xiang, W., Bertermann, D., Blum, P., 2016. A review of ground
566 investigations for ground source heat pump (GSHP) systems, *Energy Build.* 117, 160-
567 175

568 Menergy (Chinese HP manufacturer), <www.menergy.ca/about_us.html>, accessed
569 08.07.2019

570 Niemann, P., Schmitz, G., 2019. Experimental investigation of a ground-coupled air
571 conditioning system with desiccant assisted enthalpy recovery during winter mode,
572 *Appl. Therm. Eng.* 160, 114017

573 Olsson, S., 1984. The Sunclay and Kullavik Projects - Heat Storage in Clay at Low and High
574 Temperature, First E.C. Conference on Solar Heating. 894-898.

575 Pinel, P., Cruickshank, C., Beausoleil-Morrison, I., Wills, A., 2011. A review of available
576 methods for seasonal storage of solar thermal energy in residential applications, *Renew.*
577 *and Sustain. Energy Rev.* 15, 3341-3359

578 Rad, F.M., Fung, A.S., Leong, W.H., 2013. Feasibility of combined solar thermal and
579 ground source heat pump systems in cold climate, Canada, *Energy Build.* 61, 224-232.

580 Razavi, S.H., Ahmadi, R., Zahedi, A., 2018. Modelling, simulation and dynamic control of
581 solar assisted ground source heat pump to provide heating load and DHW, *Appl.*
582 *Therm. Eng.* 129, 127-144.

583 Reda, F., 2015. Long term performance of different SAGSHP solutions for residential
584 energy supply in Finland, *Appl. Energy* 144, 31-50.

585 Sarbu, I., Sebarchievici, C., 2014. General review of ground-source heat pump systems for
586 heating and cooling of buildings, *Energy build.* 70, 441-454

587 Shah, S.K., Aye, L., Rismanchi, B., 2018. Seasonal thermal energy storage system for cold
588 climate zones: A review of recent developments, *Renew. and Sustain. Energy Rev.* 97,
589 38-49

590 Si, Q., Okumiya, M., Zhang, X., 2014. Performance evaluation and optimization of a novel
591 solar-ground source heat pump system, *Energy Build.* 70, 237-245.

592 Stojanović, B., Akander, J., 2010. Build-up and long-term performance test of a full-scale
593 solar-assisted heat pump system for residential heating in Nordic climatic conditions,
594 *Appl. Therm. Eng.* 30, 188-195.

595 Trillat-Berdal, V., Souyri, B., Fraisse, G., 2006. Experimental study of a ground-coupled heat
596 pump combined with thermal solar collectors, *Energy Build.* 38, 1477-1484.

597 Verma, V., Murugesan, K., 2017. Experimental study of solar energy storage and space
598 heating using solar assisted ground source heat pump system for Indian climatic
599 conditions, *Energy Build.* 139, 569-577. Wang, E., Fung, A.S., Qi, C., Leong, W.H.,
600 2012. Performance prediction of a hybrid solar ground-source heat pump system,
601 *Energy Build.* 47, 600-611.

602 Wang, X., Zheng, M., Zhang, W., Zhang, S., Yang, T., 2010. Experimental study of a solar-
603 assisted ground-coupled heat pump system with solar seasonal thermal storage in severe
604 cold areas, *Energy Build.* 42, 2104-2110.

605 Weeratunge, H., Narsilio, G., Hoog, J., Dunstall, S., 2018. Model predictive control for a
606 solar assisted ground source heat pump system, *Energy* 152, 974-984

607 Xi, C., Lin, L., Hongxing, Y., 2011. Long term operation of a solar assisted ground coupled
608 heat pump system for space heating and domestic hot water, *Energy Build.* 43, 1835-
609 1844.

610 Xi, J., Li, Y., Liu, M., Wang, R.Z., 2017. Study on the thermal effect of the ground heat
611 exchanger of GSHP in the eastern China area, *Energy* 141, 56-65.

612 Xu, J., Wang, R., Li, Y., 2014. A review of available technologies for seasonal thermal
613 energy storage, *Sol. Energy* 103, 610-638.

614 Xu, W., Zou, Y., Xu, H.Q., et al., 2012a. Design code for heating ventilation and air
615 conditioning of civil buildings GB 50736-2012, Ministry of Housing and Urban-Rural
616 Development of the PRC.

617 Xu, W., Zou, Y., Wan, S.E., et al., 2012b. Technical specification for radiant heating and
618 cooling JGJ 142-2012, Ministry of Housing and Urban-Rural Development of the PRC.

619 Yang, W., Sun, L., Chen, Y., 2015. Experimental investigations of the performance of a
620 solar-ground source heat pump system operated in heating modes, *Energy Build.* 89,
621 97-111.

622 Yang, W.B., Shi, M.H., Dong, H., 2006, Numerical simulation of the performance of a solar-
623 earth source heat pump system, *Appl. Therm. Eng.* 26, 2367-2376.

624 You, T. Li, X., Cao, S., Yang, H., 2018. Soil thermal imbalance of ground source heat pump
625 systems with spiral-coil energy pile groups under seepage conditions and various
626 influential factors, *Energy Conversion and Management* 178, 123-136

627 Yuan, Y., Cao, X., Sun, L., Lei, B., Yu, N., 2012. Ground source heat pump system: A
628 review of simulation in China, *Renewable and Sustainable Energy Reviews* 16, 6814-
629 6822

630 Zhu, N., Wang, J., Liu, L., 2015. Performance evaluation before and after solar seasonal
631 storage coupled with ground source heat pump, *Energy Convers. Manage.* 103, 924-
632 933.